

Park Street Primary

 DNOA Decision
Signposting

Constraint description

Park Street primary T1 overloads under any outage that causes Park Street T2 to be off supply.
Park Street primary T2 overloads under any outage that causes Park Street T1 to be off supply.

Reinforcement description

Replace transformers at Park Street primary substation with 12/24 MVA units.



Constraint Season
Winter and Summer



Outage Type
N-1

Justification for decision

No flexibility requirement under Best View until 2034.

Constraint management timeline

2024 H2 Signposting

Time to Reinforce: 2 years

Constraint Type: Demand

Estimated flexibility volumes (MWh) per year under Best View:

2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
-	-	-	-	-	-	-	-	-	-	4 MWh



For more information see the Bath BSP NDP report: <https://www.nationalgrid.co.uk/dso/network-development-plan>