

Newton Abbot to Newton Abbot Main

 DNOA Decision
Reinforce with Flexibility

Constraint description

Newton Abbot Main is a three transformer primary and constrained by winter circuit ratings and summer transformer ratings. An N-1 condition on the 33 kV busbar at Newton Abbot BSP will result in the loss of two out of three of the 33/11 kV transformers/ 33 kV circuits resulting in an overload on the remaining transformer/circuit at peak loading.

Reinforcement description

Reconfiguring the 33 kV busbar running arrangement to prevent the loss of two transformers for an N-1 outage condition. Alternatively install an additional 33/11 kV transformer.



Constraint Season
Winter and Summer



Outage Type
N-1



Justification for decision

Reinforcement works are being progressed. Flexibility will be utilised as required to manage the constraint in the interim.

Constraint management timeline

2024 H2 Procurement

2024 H1 Procurement

2023 H2 Procurement

2023 H1 Procurement

Time to Reinforce: 2 years

Constraint Type: Demand

Estimated flexibility price (£/MWh) and volumes (MWh) per year under Best View:

	2024	2025	2026	2027	2028	2029
Availability	£150 / MWh 1 MWh	£115 / MWh 3 MWh	£39 / MWh 35 MWh	£37 / MWh 38 MWh	£34 / MWh 43 MWh	£33 / MWh 43 MWh
Utilisation	£9,000 / MWh 1 MWh	£6,873 / MWh 1 MWh	£2,324 / MWh 3 MWh	£2,208 / MWh 3 MWh	£2,020 / MWh 4 MWh	£2,008 / MWh 4 MWh



For more information see the **Newton Abbot BSP NDP report**: <https://www.nationalgrid.co.uk/dso/network-development-plan>