

Honiton Heathfield Primary



DNOA Decision
Signposting

Constraint description

Honiton Heathfield primary is a two transformer primary. In an N-1 outage for the loss of one of the transformers, the remaining transformer will be overloaded in the future.

Reinforcement description

Review of the ratings of both primary transformers and replace with larger units if necessary.



Constraint Season
Winter



Outage Type
N-1



Justification for decision

No flexibility requirement under Best View until 2032.

Constraint management timeline

2024 H2 **Signposting**

2024 H1 Signposting

Time to Reinforce: 3 years

Constraint Type: Demand

Estimated flexibility volumes (MWh) per year under Best View:

2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
-	-	-	-	-	-	-	-	6 MWh	50 MWh	214 MWh



For more information see the **Exeter Main BSP NDP report**: <https://www.nationalgrid.co.uk/dso/network-development-plan>