

Honiton Heathfield and Offwell Ring



DNOA Decision
Signposting

Constraint description

An N-1 condition for a fault on one leg of the Ottery St Mary – Honiton Heathfield – Offwell 33 kV ring results in an overload on the other leg of the ring.

Reinforcement description

Uprating the limiting section of circuit or modify running arrangement (removing loose couple) at Core Hill.



Constraint Season
Winter and Summer



Outage Type
N-1



Justification for decision

No flexibility requirement under Best View until 2032.

Constraint management timeline

2024 H2 **Signposting**

2024 H1 Signposting

2023 H2 Signposting

2023 H1 Signposting

Time to Reinforce: 2 years

Constraint Type: Demand

Estimated flexibility volumes (MWh) per year under Best View:

2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
-	-	-	-	-	-	-	-	4 MWh	52 MWh	293 MWh



For more information see the **Exeter Main BSP NDP report**: <https://www.nationalgrid.co.uk/dso/network-development-plan>