

Weston in Gordano Primary



DNOA Decision
Signposting

Constraint description

Weston in Gordano primary has one transformer. This transformer is predicted to overload under intact conditions.

Reinforcement description

Replace the transformer with a 7.5/15 MVA unit.



Constraint Season
Winter and Summer



Outage Type
Intact



Justification for decision

No flexibility requirement under Best View until 2032.

Constraint management timeline

2024 H2 Signposting

Time to Reinforce: 2 years

Constraint Type: Demand

Estimated flexibility volumes (MWh) per year under Best View:

2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
-	-	-	-	-	-	-	-	0.3 MWh	3 MWh	11 MWh



For more information see the **Portishead BSP NDP report**: <https://www.nationalgrid.co.uk/dso/network-development-plan>