

Asset replacement



DNOA Decision
Reinforce

Scheme description

The replacement of a significant number of assets on NGED's network is driven by the condition of the equipment rather than increased peak demand and/or generation.

The condition of assets cannot be improved by procuring flexibility services, and as such flexibility is not suitable for deferring asset replacement projects. This is discussed further in Appendix A. Asset replacement carried out by NGED on the EHV and 132 kV networks generally falls into the following categories:

- 132 kV circuit works
- 132 kV transformer/switchgear replacement
- EHV circuit works
- Primary transformer/switchgear replacement

Fault level



DNOA Decision
Reinforce

Scheme description

Fault level driven reinforcement is carried out by NGED to keep fault levels below the ratings of assets on the network (including circuit breakers and busbars).

These reinforcement schemes ensure generation customers can continue to connect on that part of the network, and allow for more secure running arrangements to be utilised to improve security of supply.

Flexibility is not suitable to mitigate fault level constraints, and therefore cannot be used to defer fault level reinforcement.

The following fault level schemes are planned on the EHV and 132 kV networks in NGED's four licence areas:

East Midlands

Bourne BSP
Coventry 132 kV
Cox Street Primary
Hazelwood Primary
Ketton Cement Primary
Rugby BSP
Staveley 11 kV
Willington 132 kV



South Wales

Cardiff East
Rassau



West Midlands

Bustleholm GSP
Feckenham
Kitwell 132 kV
Roushill Primary
Ryeford BSP
Strensham
Wolverampton 33 kV



South West

Exeter Main GSP
Haven Road 11 kV
Indian Queens GSP
Melksham GSP
Sowton BSP
Weston BSP



Generation



DNOA Decision
Reinforce

Scheme description

Across NGED's four licence areas significant growth in distributed generation is projected, which can lead to constraints on the distribution network.

These constraints were not deemed technically suitable for mitigation using Demand Turn Up / Generation Turn Down services.

The following generation reinforcement schemes are planned on the EHV and 132 kV networks in NGED's four licence areas:

East Midlands

- Alfreton to Ravensdale Park
- Ashby/Willesley
- Bicker Fen GSP
- Harbury Network
- Mansfield to Skegby Lane T1
- Staythorpe GSP
- Whitwell BSP
- Worthington Primary



West Midlands

- Hereford to Ludlow Mesh
- Evesham to Strensham
- Feckenham to Evesham



South Wales

- Margam BSP
- Swansea North/Upper Boat



South West

- A Route
- B Route
- Callington to Landulph
- Exeter City to Makro
- Exeter Main GSP
- Fraddon BSP
- Haven Road 11kV
- Indian Queens GSP
- Landulph BSP
- Melksham GSP

- Plympton to Torycombe
- Polzeath to Wadebridge
- Pyworthy BSP
- Radstock to Evercreech
- Rame BSP
- Sowton BSP
- St Austell BSP
- St Germans BSP
- St Tudy BSP
- Watchfield Ring
- Weston BSP



Voltage



Scheme description

Many of the constraints identified on the network across NGED's four licence areas are related to voltages dropping below statutory limits.

Managing voltage constraints using flexibility services is possible. However, for more severe voltage constraints the fact that only real power (MW) is procured becomes a limiting factor. This is due to the fact that procuring real power without reactive power (MVar) leads to a reduction in power quality (the power factor for the network drops).

The following voltage constraints have been identified which are not suitable for mitigation with flexibility under NGED's current processes:

East Midlands

Alfreton to Ravensdale Park

South Holland to Long Sutton and Holbeach



South Wales

Llandrindod to Rhayader

Pembroke to Broadfield

Abergavenny to Glasbury



West Midlands

Feckenham to Evesham and Strensham

Hinksford to Wribbenhall

Ironbridge to Star Aluminium



South West

Barnstaple to South Molton

Camborne Holmans

Feeder Road

Hayle BSP

Lapford and Tinkers Cross

St Tudy to Davidstow

